BV LCIE CHINA Number N° 2466AS01GYB53018

ATTESTATION
of conformity with European Directives

Product:	**RCCB**
Reference	**GYL8 Series**
Issued to	**ZHEJIANG GEYA ELECTRICAL CO., LTD**
Address	**Wenzhou Bridge Industral Zone, Beibaixiang Twon, Yueqing City, Zhejiang Province, China 325603**
Manufacturer	**ZHEJIANG GEYA ELECTRICAL CO., LTD**
Technical characteristics	**1P+N and 3P+N(neutral on right)** **Ue=240V~(1P+N); 415V~(3P+N), 50Hz** **In=16A, 20A, 25A, 32A, 40A, 50A, 63A** **Inc=IΔc=6000A** **Im=IΔm=500A for 16A, 20A, 25A, 32A, 40A, 50A; 10In for 63A** **IΔn=30mA; 100mA; 300mA** **Grid distance = 50mm** **Ui= 500V; Uimp=4kV** **Material group=IIIa; Screw diameter=5,9mm**

The submitted sample of the above equipment has been tested for CE marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	*Report number*	*Report date*
EN 61008-1:2012+A1:2014+A2:2014+A11:2015 +A12:2017 **EN 61008-2-1:1994+A11:1998**	**B230097**	**08/11/2023**

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The CE marking may be affixed if all relevant and effective European Directives with CE are applicable

Shanghai (P.R. China), Jan. 5th, 2024.

Charlie CHEN
Product Line Manager

CE

be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai P.R.C (201612)
Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com